



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200305006887

Product Electronic Overload Relay

Applicant NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Type/Model Ex9RE40;

Technical data Ui:690V; Uimp:6kV;Ue:690V;Us:
AC/DC24V,AC110V,AC220V;Ie:0.1-0.5A,0.4-2A,1.8-9A,8-40A;t
rip class: 5,10,20,30; 3P;IP20(except for the line);Auxiliary
contact:(body contact):1NO,1NC;Ith:3A;AC-15:AC250V/3A,
DC-13:DC30V/3A

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0305-011075, the submitted sample(s) of the above item complies
with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jul.29,2020

Valid until: Jul.29,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>