



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220305007621

Product AC Contactor

Applicant NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Type/Model Ex9C25,Ex9C32,Ex9C38,Ex9C25F,Ex9C32F,Ex9C38F,Ex9
CA25,Ex9CA32,Ex9CA38,
Ex9CR25,Ex9CR32,Ex9CR38,Ex9CR25F,Ex9CR32F,Ex9C
R38F;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2021CQC0305-012401, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Mar.29,2022

Valid until: Mar.28,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

CE 0012034



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE220305007621

Ex9C25, Ex9C32, Ex9C38, Ex9C25F, Ex9C32F, Ex9C38F, Ex9CA25, Ex9CA32, Ex9CA38,
Ex9CR25, Ex9CR32, Ex9CR38, Ex9CR25F, Ex9CR32F, Ex9CR38F

Uimp: 6kV;

Ui: 690V;

Ue: AC220V/230V/240V, AC380V/400V/415V, AC660V/690V;

Ex9C25, Ex9C25F, Ex9CA25, Ex9CR25, Ex9CR25F:

Ith: 40A;

AC-1: Ue/Ie: 660V/690V/40A;

AC-3: Ue/Ie: 220V/230V/240V/25A, 380V/400V/415V/25A, 660V/690V/17.3A;

AC-4: Ue/Ie: 220V/230V/240V/25A, 380V/400V/415V/25A, 660V/690V/14A;

Ex9C32, Ex9C32F, Ex9CA32, Ex9CR32, Ex9CR32F:

Ith: 50A;

AC-1: Ue/Ie: 660/690V/50A;

AC-3: Ue/Ie: 220V/230V/240V/32A, 380V/400V/415V/32A, 660V/690V/21.9A;

AC-4: Ue/Ie: 220V/230V/240V/32A, 380V/400V/415V/32A, 660V/690V/17.3A;

Ex9C38, Ex9C38F, Ex9CA38, Ex9CR38, Ex9CR38F:

Ith: 50A;

AC-1: Ue/Ie: 660V/690V/50A;

AC-3: Ue/Ie: 220V/230V/240V/38A, 380V/400V/415V/38A, 660V/690V/21.9A;

AC-4: Ue/Ie: 220V/230V/240V/38A, 380V/400V/415V/32A, 660V/690V/17.3A;

Us:

Ex9C25~38, Ex9CA25~38, Ex9CR25~38: AC 24V, 36V, 42V, 48V, 110V, 120V, 127V,

220V, 230V, 240V, 277V, 380V, 400V, 415V, 440V, 460V, 480V, 600V, 660V, 50/60Hz, 50Hz;

Ex9C25F~38F, Ex9CR25F~38F: AC(50/60Hz)/DC 100V~250V, 48V~130V, 24V~60V;

3P, 4P (4NO, 2NO+2NC);

IP20 (Front side);

Auxiliary contacts:



CHINA QUALITY CERTIFICATION CENTRE





**CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY**

Appendix

Page 2 of 2


Certificate No.: CE220305007621

2NO2NC,1NO1NC,2NO,2NC,2NO1NC,1NO2NC,1NO,1NC;

Ith: 10A;

AC-15: Ue/Ie: AC380V/400V/415V/1.9A;

DC-13: Ue/Ie: DC220V/250V/0.31A;



CHINA QUALITY CERTIFICATION CENTRE

