



Ref. Certif. No.

CN54666

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal Overload Relay

Name and address of the applicant

NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the manufacturer

NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:6kV;Ui: 690V;Ue: 690V;  
Ie:0.63-1A,1-1.6A,1.6-2.5A,2.5-4A,4-6A,5.5-8A,7-10A,9-13A,12-18A,16-24A,23-32A,30-38A;  
Trip class:10A;3P;IP20(Front side); Auxiliary contact:(body contact)  
Ith:5A;AC-15:Ue/Ie:220V/1.64A,380V/0.95A; DC-13:Ue/Ie:220V/0.13A;1NO1NC

Trademark / Brand (if any)

NOARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Ex9R38;

Additional information (if necessary may also be reported on page 2)

IEC 60947-4-1:2018

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097660

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



Date: Sep.09,2021

Signature:

Xie ZhaoXu

CB 0064306